



(images are illustrative only and do not override other information provided)

### NOTES

1. A SOIL TEST & BUILDING PERMIT SHALL BE CONDUCTED FIRST BEFORE ANY SHELTER STRUCTURE IS ERECTED.
2. AS A MINIMUM, NOMINATED SHELTER SHALL BE AT LEAST 4 x 4m IN SIZE, WITH A SKILLION ROOF STYLE. EXACT SIZE SHOULD RELATE TO WHAT IS UNDER THE STRUCTURE AND PROVIDE ADEQUATE PROTECTION TO ANY FURNITURE.
3. STRUCTURE MUST BE SUPPLIED WITH FULL STRUCTURAL DESIGN & DOCUMENTATION CERTIFIED BY AN APPROPRIATELY ACCREDITED PROFESSIONAL.
4. PAVING PAD UNDERNEATH SHELTER SHALL HAVE AT LEAST A 1m APRON OFFSET FROM THE ROOFLINE OF SHELTER
5. WHERE TIMBER IS USED, IT MUST BE RATED FOR A MINIMUM DURABILITY OF CLASS 2.
6. MATERIAL CONSIDERATIONS ARE ASSESSED ON A CASE BY CASE BASIS, HOWEVER ARE EXPECTED TO BE ROBUST & APPROPRIATE TO OUTDOOR CONDITIONS & LOCAL CLIMATE.
7. AS A MINIMUM, TIMBER POST SHALL BE 125x125mm IN SIZE AND STAINED WITH CABBOTS AQUA DECK MERBAU STAIN.
8. ROOFING SHALL BE COLORBOND WOODLAND GREY OR APPROVED EQUIVALENT.
9. ORIENTATION SHALL BE DETERMINED BY THE MAXIMUM SHADE PROTECTION.
10. SHELTER POST SHALL BE INSTALLED ON FULL STIRRUPS POST ANCHORS. ANTI-VANDAL GALVANISED FIXINGS & BRACKETS ARE RECOMMENDED.